




N.°	REVISIÓN	FECHA	AUT.

Nos reservamos el derecho de propiedad intelectual sobre este documento y los archivos adjuntos, así como el envío a terceros no está permitida, salvo consentimiento por escrito, así nos responde civil y penalmente ante la ley.




GERENCIA DE SUBESTACIONES
 SE REVISÓ EN CUANTO A CARACTERÍSTICAS ELÉCTRICAS Y DIMENSIONES, SIN QUE ESTO EXIJA QUE DEBE CUMPLIR SATISFACTORIAMENTE CON LAS PRUEBAS DEL LAPEN, PARA SU APROBACIÓN FINAL.
ATENTAMENTE

GERENTE
 FECHA: 27 OCT 2016

CARACTERÍSTICAS DIMENSIONALES

DISTANCIA NOMINAL DE FUGA	mm	850
DISTANCIA DE FLAMEO EN SECO	mm	340

CARACTERÍSTICAS MECÁNICAS

RESISTENCIA A LA FLEXIÓN	N	8000
RESISTENCIA A LA TORSIÓN	N.m	2000

CARACTERÍSTICAS ELÉCTRICAS


TENSIÓN SOPORTABLE BAJO LLUVIA	kV	70
TENSIÓN SOPORTABLE DE MANIOBRA	kV	-
TENSIÓN SOPORTABLE DE IMPULSO	kV	170

PESO NETO	kg	14
-----------	----	----

NOTAS :

- 1-TOLERANCIA Y PRUEBAS DE ACUERDO CON LA NORMA IEC 60168/273.
- 2-NÚMERO DE ALETAS : 7
- 3-ACABAMIENTO PARTES METÁLICAS : GALVANIZADO A CALIENTE, DE ACUERDO CON LA NORMA ASTM A-153.
- 4-DIMENSIONES EN MILÍMETROS.
- 5-COLOR : MARRÓN Ó GRIS.
- 6-EMPAQUE, EMBALAJE, EMBARQUE, TRANSPORTE, DESCARGA, RECEPCIÓN Y ALMACENAMIENTO DE BIENES MUEBLES ADQUIRIDOS POR CFE, DE ACUERDO A LA ESPECIFICACIÓN CFE-L1000-11.



TÍTULO: AISLADOR SOPORTE PORCELANA NBAI 170kV	 PPC SANTANA			IDENTIFICACIÓN REFERENCIA -	
	ELAB./FECHA 13/09/16	VER./FECHA 13/09/16	APROV./FECHA 13/09/16	REVISIÓN -	
ORIGEN: PROYECTO SANTANA (CFE 52810-32 - CORTA CP8-170-II)	CÓD. CAD: G.PROJ\UNI-02\STATION\A033			FOLHA -	ESCALA -
CÓD. 8.8172.65			TIPO- CAED		

FECHA AUT.
REVISION
N.º









CFE
 GERENCIA DE SUBESTACIONES

SE REVISÓ EN CUANTO A CARACTERÍSTICAS ELÉCTRICAS Y DIMENSIONES, SIN QUE ESTO EXIJA QUE DEBE CUMPLIR SATISFACTORIAMENTE CON LAS PRUEBAS DEL LAPEN, PARA SU APROBACIÓN FINAL.

ATENTAMENTE.

FECHA: 27 OCT 2016

GERENTE



PPC SANTANA

NOTAS:

- 1- PLANOS MERAMENTE ILUSTRATIVOS.
- 2- LA COMPOSICIÓN DE LOS BULTOS PUEDEN VARIAR DE ACUERDO CON LAS DIMENSIONES DE LOS AISLADORES.
- 3- PLANOS MERAMENTE ILUSTRATIVOS.
- 4- UTILIZACIÓN PARA LOS AISLADORES MACIZOS.
- 5- EMPAQUE, EMBALAJE, EMBARQUE, TRANSPORTE, DESCARGA, RECEPCIÓN Y ALMACENAMIENTO DE BIENES MUEBLES ADQUIRIDOS POR CFE, DE ACUERDO A LA ESPECIFICACIÓN CFE-L1000-11.

TÍTULO:	PPC SANTANA			IDENTIFICACIÓN	
EMBALAJE HORIZONTAL				REFERENCIA X212	
ORIGEN:	ELAB./FECHA	VER./FECHA	APROV./FECHA	REVISIÓN	
PROYECTO SANTANA	28/10/16	28/10/16	28/10/16	-	
	CÓD. CAD: G:PROJ\DIVERSOS\DVDVX210			FOLHA	ESCALA
	CÓD. -			-	-
	TIPO- DVDV				



The logo graphic for LACTEC, featuring a stylized white swirl that loops around the letters. A small yellow star is positioned above the letter 'A'.
LACTEC



INSTITUTO DE TECNOLOGIA
PARA O DESENVOLVIMENTO

REPORT

DOCUMENT N°

UTAT - 043 / 2004

ADDRESS:

Centro Politécnico UFPR - P.O. Box 19067 - CEP 81531-980 - Curitiba - PR - Brazil
Phone: +55 41 361-6200 Fax: +55 41 266-3582 E-mail: lactec@lactec.org.br

ISSUED

February 20, 2004

PAGE

1 of 5

TITLE:

DRY LIGHTNING IMPULSE FLASHOVER VOLTAGE TEST
DRY LIGHTNING IMPULSE WITHSTAND VOLTAGE TEST
DRY POWER FREQUENCY FLASHOVER VOLTAGE TEST
DRY POWER FREQUENCY WITHSTAND VOLTAGE TEST
WET POWER FREQUENCY FLASHOVER VOLTAGE TEST
WET POWER FREQUENCY WITHSTAND VOLTAGE TEST
RADIO INFLUENCE VOLTAGE TEST
CORONA EXTINCTION VOLTAGE TEST
MECHANICAL STRENGTH TEST

SCOPE:

STATION POST INSULATOR - SOLID CORE
MANUFACTURER: SANTANA
TYPE: IEC 168 / 273 - CLASS C10 - 200 -II
BIL: 200 KV
DRAWING NUMBER: CODE 8.1022.65
NUMBER OF TEST SPECIMEN:
ELECTRICAL TESTS: 01
MECHANICAL TEST: 03



SERVICE ORDER:

CUSTOMER:

ISOLADORES SANTANA S. A.
RUA ANTONIO PEDRO, 645
13920-000 - PEDREIRA - SP - BRAZIL


NUMBER OF ANNEXES:

06

REPORT BY:

Carlos Y. Nakaguishi
Electrical Engineer - CREA 8547-D(PR)

CHECKED BY:



Carlos Y. Nakaguishi
Electrical Engineer - CREA 8547-D(PR)

APPROVED BY:



High Voltage Unit

"The results of this test report apply only to the items tested/analysed"

THIS DOCUMENT AND THE CONTENTS HEREIN MAY NOT BE REPRODUCED OTHER THAN IN FULL EXCEPT WITH THE PERMISSION OF LACTEC

ADDRESS:

Centro Politécnico UFPR - P.O. Box 19067 - CEP 81531-980 - Curitiba - PR - Brazil
Phone: +55 41 361-6200 Fax: +55 41 266-3562 E-mail: lactec@lactec.org.br

ISSUED

February 20, 2004

PAGE

2 of 5

1. INTRODUCTION

1.1- Test(s) / Analysis(es) performed:

- DRY LIGHTNING IMPULSE FLASHOVER VOLTAGE TEST
- DRY LIGHTNING IMPULSE WITHSTAND VOLTAGE TEST
- DRY POWER FREQUENCY FLASHOVER VOLTAGE TEST
- DRY POWER FREQUENCY WITHSTAND VOLTAGE TEST
- WET POWER FREQUENCY FLASHOVER VOLTAGE TEST
- WET POWER FREQUENCY WITHSTAND VOLTAGE TEST
- RADIO INFLUENCE VOLTAGE TEST
- CORONA EXTINCTION VOLTAGE TEST
- MECHANICAL STRENGTH TEST

1.2- Test Equipment:

- VOLTAGE IMPULSE GENERATOR, HAEFELY, TYPE V3200/160
- DAMPED CAPACITIVE VOLTAGE DIVIDER, HAEFELY, TYPE CR 3200
- PEAK VOLTMETER, HAEFELY, TYPE SV64M, N° 080255-31-80
- DIGITAL OSCILLOSCOPE, TEKTRONIX, MODEL 744A, N° B040680
- MOTOR GENERATOR, 60 HZ, 6900 V, N° 57222
- TEST TRANSFORMER, ASEA, TYPE TMZ-17, N° 7219634
- SERIES RESONANT SYSTEM, HIPOTRONICS, TYPE 7300-750SR
- PEAK VOLTMETER, HAEFELY, TYPE SV64M, N° 080255-31-80
- ARTIFICIAL RAIN EQUIPMENT, MWB, TYPE R200, N° 772797
- COUPLING CAPACITOR, MICALFIL, 1000 PF, N° 0026119
- FIELD INTENSITY METER, SINGER, TYPE NM 17/27, N° 04072

1.3- Date of Test:

- November, 24-26, 2003
- December 15, 2003
- February, 10-11, 2004 (Mechanical Strength Test)

1.4- Place:

- LACTEC/DPEL -High Voltage Laboratory
- ISOLADORES SANTANA S/A - PEDREIRA - SP

1.5- Tested by:

- Celso Luis de Lima Martins
- Edson Pasqualim
- Carlos Eduardo Ribas
- Michel Lucio Garcia
- Nilson de Oliveira

1.6- Witnessed / Inspected by:

- Marcelo Acorsi (SANTANA)



ADDRESS:

Centro Politécnico UFPR - P.O. Box 19067 - CEP 81531-980 - Curitiba - PR - Brazil
Phone: +55 41 361-6200 Fax: +55 41 266-3582 E-mail: lsctec@lactec.org.br

ISSUED

February 20, 2004

PAGE

3 of 5

2. REFERENCES

IEC 60168, "Tests on Indoor and Outdoor Post Insulators of Ceramic Material or Glass for Systems with Nominal Voltages Greater than 1000 V", IEC, Geneve

IEC 60273, "Characteristics of Indoor and Outdoor Post Insulators for Systems with Nominal Voltages Greater than 1000 V", IEC, Geneve

AS 1137, Part 3 - 1981, "Insulators - Porcelain and Glass Indoor and Outdoor Station Post Insulators (for voltages greater than 1000 Vac)", SAA, Sidney - Australia

3. TEST DESCRIPTION

3.1- Dry Lightning Impulse Flashover Voltage Test

In the test specimen, the voltage corresponding to a 50 percent disruptive discharge probability V50%, both polarity, was determined by the up-and-down method, with 30 applications.

The following results were obtained:

Test Specimen	V50% (+)	V50% (-)
# 01	248.3 kV	452.4 kV

A complete set of test results is enclosed in Annex 01.



3.2- Dry Lightning Impulse Withstand Voltage Test

Fifteen consecutive impulses of both polarity and peak voltage of 230 kV, with appropriate atmospheric corrections were applied to the test specimen.

No puncture or flashover was observed during the test.

A complete set of test results is enclosed in Annex 02.

3.3- Dry Power Frequency Flashover Voltage Test

In the test specimen, the dry power frequency flashover voltage was determined by averaging five flashover voltages.

The average flashover voltage was corrected to standard atmospheric conditions.

The following results were obtained:

Test Specimen	Average
# 01	157 kV

A complete set of test results is enclosed in Annex 03.

No puncture was observed during the test.

3.4- Dry Power Frequency Withstand Voltage Test

The rated dry power frequency withstand voltage of 135 kV, with appropriate atmospheric corrections was applied to the test specimen during 60 seconds.

A complete set of test results is enclosed in Annex 03.

No puncture or flashover was observed during the test.

3.5- Wet Power Frequency Flashover Voltage Test

In the test specimen, the wet power frequency flashover voltage was determined by averaging five flashover voltages.

The average flashover voltage was corrected to standard atmospheric conditions.

The following results were obtained:

Test Specimen	Average
# 01	85 kV

A complete set of test results is enclosed in Annex 04.

No puncture was observed during the test.



3.6- Wet Power Frequency Withstand Voltage Test

The rated dry power frequency withstand voltage of 75 kV, with appropriate atmospheric corrections was applied to the test specimen during 60 seconds.

A complete set of test results is enclosed in Annex 04.

No puncture or flashover was observed during the test.

3.7- Radio Influence Voltage Test

The test specimen was tested using a Field Intensity Meter at 1000 kHz, with a measuring impedance of 150 Ω .

The radio interference voltage measured at 28.6 kV (phase-ground) test voltage was the following:

Test Specimen	RIV @ 28.6 kV (Zm=150 Ω , fm= 1000 kHz)
# 01	11.2 μ V

A complete set of test results is enclosed in Annex 05.

3.8- Corona-Extinction Voltage Test

The corona-extinction voltage of the test specimen was determined.

Test Specimen	Corona-Inception Voltage	Corona-Extinction Voltage
# 01	88 kV	82 kV

3.9- Mechanical Strength Test

Three test specimens were subjected to the mechanical strength test, comprising bending and torsion tests.

The following results were obtained:

A) Bending Test

Test Specimen	Bending Strength	Test	Result
# 01	10000 N	14800 N	Porcelain breakage
# 02	10000 N	13330 N	Porcelain breakage
# 03	10000 N	12940 N	Porcelain breakage

B) Torsion Test

Test Specimen	Torsional Strength	Test	Result
# 01	2500 N.m	2770 N.m	No breakage
# 02	2500 N.m	2810 N.m	No breakage
# 03	2500 N.m	2600 N.m	No breakage



4. DRAWING

Drawing number CODE 8.1022.65, furnished by the customer, is enclosed in this report as Annex 06.



INSTITUTO DE TECNOLOGIA
PARA O DESENVOLVIMENTO

REPORT

UTAT - 043/04


ANNEX / PAGE

Annex 01 / Page 01 of 02

DRY LIGHTNING IMPULSE FLASHOVER VOLTAGE TEST

CUSTOMER SANTANA	MANUFACTURER SANTANA	TYPE 8.1022.65	NOMINAL VOLTAGE kV
SPECIMEN # 01	POLARITY (+)	TEST TYPE <input checked="" type="checkbox"/> DRY <input type="checkbox"/> WET	DRY ARCING DISTANCE 0.370 m
NUMBER OF STAGES (IMP. GEN.) 4s/1p	VOLTAGE DIVIDER CR 3200	SCALE FACTOR 528.1	WAVE FORM 1.04 / 46.0
DRY-BULB THERMOMETER 22.1 °C	WET-BULB THERMOMETER 19.6 °C	ATMOSPHERIC PRESSURE 681.2 mmHg	CORRECTION FACTOR 0.930

VOLTAGE WAVE FORM



HORIZONTAL: 10 µs/div

APPLIC.	CHARGING VOLTAGE (kV)	CREST VOLTAGE (kV)	PROSPEC. VOLTAGE (kV)	CORRECTED VOLTAGE (kV)	TIME TO CHOPPING (µs)	APPLIC.	CHARGING VOLTAGE (kV)	CREST VOLTAGE (kV)	PROSPEC. VOLTAGE (kV)	CORRECTED VOLTAGE (kV)	TIME TO CHOPPING (µs)
1	62.0	232.3	232.3	249.8	9.9	21	62.0	232.0	232.0	249.5	9.1
2	60.1	224.7	224.7	241.6	-	22	60.1	224.8	224.8	241.7	9.8
3	62.0	231.9	231.9	249.4	-	23	58.2	217.4	217.4	233.8	-
4	63.9	239.5	239.5	257.5	7.4	24	60.1	225.1	225.1	242.0	-
5	62.0	231.8	231.8	249.2	-	25	62.0	232.3	232.3	249.8	8.5
6	63.9	239.5	239.5	257.5	-	26	60.1	224.8	224.8	241.7	10.4
7	65.8	246.2	246.2	264.7	6.6	27	58.2	218.0	218.0	234.4	-
8	63.9	239.5	239.5	257.5	8.0	28	60.1	225.0	225.0	241.9	-
9	62.0	231.8	231.8	249.2	-	29	62.0	232.5	232.5	250.0	-
10	63.9	239.5	239.5	257.5	7.8	30	63.9	239.6	239.6	257.6	8.6
11	62.0	231.9	231.9	249.4	7.9						
12	60.1	225.0	225.0	241.9	-						
13	62.0	232.3	232.3	249.8	9.8						
14	60.1	225.0	225.0	241.9	-						
15	62.0	232.2	232.2	249.7	9.8						
16	60.1	225.0	225.0	241.9	-						
17	62.0	232.3	232.3	249.8	-						
18	63.9	239.4	239.4	257.4	7.7						
19	62.0	232.4	232.4	249.9	7.9						
20	60.1	224.9	224.9	241.8	-						



50% DISRUPTIVE DISCHARGE VOLTAGE (V50%)

248.3 kV

WITHSTAND VOLTAGE EVALUATED FROM V50%

238.6 kV

REMARKS

Curitiba, December 15, 2003

CHECKED BY

[Signature]



INSTITUTO DE TECNOLOGIA
PARA O DESENVOLVIMENTO

REPORT

UTAT - 043/04


ANNEX / PAGE

Annex 01 / Page 02 of 02

DRY LIGHTNING IMPULSE FLASHOVER VOLTAGE TEST

CUSTOMER SANTANA	MANUFACTURER SANTANA	TYPE 8.1022.65	NOMINAL VOLTAGE kV
SPECIMEN # 01	POLARITY (-)	TEST TYPE <input checked="" type="checkbox"/> DRY <input type="checkbox"/> WET	DRY ARCING DISTANCE 0.370 m
NUMBER OF STAGES (IMP. GEN.) 4s/1p	VOLTAGE DIVIDER CR 3200	SCALE FACTOR 528.1	WAVE FORM 1.03 / 45.5
DRY-BULB THERMOMETER 22.1 °C	WET-BULB THERMOMETER 19.7 °C	ATMOSPHERIC PRESSURE 681.6 mmHg	CORRECTION FACTOR 0.890

VOLTAGE WAVE FORM



HORIZONTAL: 10 μs/div

APPLIC.	CHARGING VOLTAGE (kV)	CREST VOLTAGE (kV)	PROSPEC. VOLTAGE (kV)	CORRECTED VOLTAGE (kV)	TIME TO CHOPPING (μs)	APPLIC.	CHARGING VOLTAGE (kV)	CREST VOLTAGE (kV)	PROSPEC. VOLTAGE (kV)	CORRECTED VOLTAGE (kV)	TIME TO CHOPPING (μs)
1	107.6	402.5	402.5	452.2	5.0	21	107.6	401.9	401.9	451.6	2.9
2	104.4	390.5	390.5	438.8	-	22	104.4	390.5	390.5	438.8	-
3	107.6	401.7	401.7	451.3	2.6	23	107.6	401.4	401.4	451.0	2.5
4	104.4	389.5	389.5	437.6	-	24	104.4	390.5	390.5	438.8	-
5	107.6	402.6	402.6	452.4	4.1	25	107.6	401.7	401.7	451.3	-
6	104.4	390.7	390.7	439.0	-	26	110.8	414.3	414.3	465.5	4.8
7	107.6	402.3	402.3	452.0	2.9	27	107.6	401.8	401.8	451.5	-
8	104.4	391.0	391.0	439.3	2.8	28	110.8	414.5	414.5	465.7	4.7
9	101.2	378.7	378.7	425.5	-	29	107.6	401.5	401.5	451.1	-
10	104.4	390.4	390.4	438.7	-	30	110.8	414.1	414.1	465.3	2.7
11	107.6	402.1	402.1	451.8	-						
12	110.8	414.5	414.5	465.7	3.3						
13	107.6	401.4	401.4	451.0	-						
14	110.8	414.5	414.5	465.7	3.1						
15	107.6	402.1	402.1	451.8	-						
16	110.8	414.9	414.9	466.2	-						
17	114.0	426.1	426.1	478.8	2.8						
18	110.8	414.4	414.4	465.6	3.4						
19	107.6	402.1	402.1	451.8	-						
20	110.8	414.7	414.7	466.0	3.9						



50% DISRUPTIVE DISCHARGE VOLTAGE (V50%)

452.4 kV

WITHSTAND VOLTAGE EVALUATED FROM V50%

434.8 kV

REMARKS

Curitiba, December 15, 2003

CHECKED BY

a



**INSTITUTO DE TECNOLOGIA
PARA O DESENVOLVIMENTO**

REPORT

UTAT - 043/04


ANNEX / PAGE

Annex 02 / Page 01 of 01

DRY LIGHTNING IMPULSE WITHSTAND VOLTAGE TEST

CUSTOMER SANTANA	MANUFACTURER SANTANA	TYPE 8.1022.65	NOMINAL VOLTAGE kV
SPECIMEN # 01	WITHSTAND VOLTAGE 230 kV	TEST TYPE <input checked="" type="checkbox"/> DRY <input type="checkbox"/> WET	DRY ARCING DISTANCE 0.370 m
NUMBER OF STAGES (IMP. GEN.) 4s/1p	VOLTAGE DIVIDER CR 3200	SCALE FACTOR 528.1	WAVE FORM 1.06 / 46.0
DRY-BULB THERMOMETER 22.0 °C	WET-BULB THERMOMETER 19.7 °C	ATMOSPHERIC PRESSURE 680.6 mmHg	CORRECTION FACTOR 0.917

VOLTAGE WAVE FORM



HORIZONTAL: 10 µs/div

POSITIVE POLARITY						NEGATIVE POLARITY					
APPLIC.	CHARGING VOLTAGE (kV)	CREST VOLTAGE (kV)	PROSPEC. VOLTAGE (kV)	CORRECTED VOLTAGE (kV)	TIME TO CHOPPING (µs)	APPLIC.	CHARGING VOLTAGE (kV)	CREST VOLTAGE (kV)	PROSPEC. VOLTAGE (kV)	CORRECTED VOLTAGE (kV)	TIME TO CHOPPING (µs)
1	57.0	213.5	213.5	232.8	-	1	57.0	211.0	211.0	230.1	-
2	57.0	211.0	211.0	230.1	-	2	57.0	211.4	211.4	230.5	-
3	57.0	211.2	211.2	230.3	-	3	57.0	211.5	211.5	230.6	-
4	57.0	213.9	213.9	233.3	-	4	57.0	211.0	211.0	230.1	-
5	57.0	211.2	211.2	230.3	-	5	57.0	211.1	211.1	230.2	-
6	57.0	210.9	210.9	230.0	-	6	57.0	211.1	211.1	230.2	-
7	57.0	211.0	211.0	230.1	-	7	57.0	211.5	211.5	230.6	-
8	57.0	210.9	210.9	230.0	-	8	57.0	214.2	214.2	233.6	-
9	57.0	211.1	211.1	230.2	-	9	57.0	211.6	211.6	230.8	-
10	57.0	211.0	211.0	230.1	-	10	57.0	214.9	214.9	234.4	-
11	57.0	214.1	214.1	233.5	-	11	57.0	214.9	214.9	234.4	-
12	57.0	210.8	210.8	229.9	-	12	57.0	215.0	215.0	234.5	-
13	57.0	214.1	214.1	233.5	-	13	57.0	214.4	214.4	233.8	-
14	57.0	213.9	213.9	233.3	-	14	57.0	215.0	215.0	234.5	-
15	57.0	214.1	214.1	233.5	-	15	57.0	214.6	214.6	234.0	-



REMARKS

Curitiba, December 15, 2003

CHECKED BY
a



RADIO INFLUENCE VOLTAGE TEST


CUSTOMER	TEST OBJECT	TYPE	MANUFACTURER
SANTANA	INSULATOR	8.1022.65	SANTANA
REFERENCE	MEASUREMENT FREQUENCY	DRY-BULB THERMOMETER	RELATIVE HUMIDITY
	1000 kHz	25.4 °C	46.9 %
		MEASUREMENT IMPEDANCE - Zm	ATMOSPHERIC PRESSURE
		150 Ω	678.4 mmHg

CHARACTERISTICS OF THE RIV METER

MANUFACTURER: SINGER STODDART
 TYPE: NM-17/27 N° 0146-04072
 FREQUENCY RANGE: FROM 10 KHz TO 32 MHz
 INSTRUMENT FACTOR 0dB = 1 μV
 MEASUR. RANGE: FROM 0 TO 160 dB ABOVE 1μV
 PRECISION: 3 dB (IMPULSIVE SIGNALS)
 BANDWIDTH (6 dB): 10 KHz
 INTERNAL IMPEDANCE: 50 Ω
 QUASI-PEAK DETECTOR (tc = 1 ms and td = 600 ms)

DETERMINATION OF THE CORRECTION FACTOR

DIAGRAM



ARRANGEMENT	APPLIED V (A)		MEASURED V (B)		CORRECTION FACTOR dB (A - B)	REMARKS
	Sw1-clos	Sw2-open	Sw1-open	Sw2-closed		
	120		109		11	
	110		100		10	Average = 10 dB @ 1 MHz
	100		90		10	




REMARKS	Curitiba, November 24, 2003	
	CHECKED BY	



RADIO INTERFERENCE VOLTAGE TEST

CUSTOMER SANTANA	TEST OBJECT INSULATOR	TYPE 8.1022.65	MANUFACTURER SANTANA
DRAWING	MEASUREMENT FREQUENCY 1000 kHz	DRY-BULB THERMOMETER 25.4 °C	RELATIVE HUMIDITY 46.9 %
TEST SPECIMEN #1	MEASUREMENT IMPEDANCE - Z_m 150 Ω	ATMOSPHERIC PRESSURE 678.4 mmHg	





VOLTAGE (kV)	TEST SPECIMEN #1				II				III			
	MEAS dB	C.F	COR dB	μV	MEAS dB	C.F	COR dB	μV	MEAS dB	C.F	COR dB	μV
28.6	11	10	21	11.2								
26.0	11	10	21	11.2								
23.4	11	10	21	11.2								
20.8	11	10	21	11.2								
18.2	11	10	21	11.2								
15.6	11	10	21	11.2								
18.2	11	10	21	11.2								
20.8	11	10	21	11.2								
23.4	11	10	21	11.2								
26.0	11	10	21	11.2								
28.6	11	10	21	11.2								
26.0	11	10	21	11.2								
23.4	11	10	21	11.2								
20.8	11	10	21	11.2								
18.2	11	10	21	11.2								
15.6	11	10	21	11.2								
0.0	11	10	21	11.2								



REMARKS	Curitiba, November 24, 2003	
	CHECKED BY	

GENERAL	28-09-99	LUS
REVISION	DATE	AUT.
N.º		



YEAR / MONTH / SERIAL No.

DIMENSIONAL CHARACTERISTICS

LEAKAGE DISTANCE	mm	950
PROTECTED DISTANCE 90°	mm	400
DRY ARCING DISTANCE	mm	370

MECHANICAL CHARACTERISTICS

CANTILEVER STRENGTH	N	10000
TORSIONAL STRENGTH	N.m	2500

ELECTRICAL CHARACTERISTICS

POWER FREQUENCY WITHSTAND (WET)	kV	70
SWITCHING IMPULSE WITHSTAND (WET)	kV	-


PACKING CHARACTERISTICS

UNIT NET WEIGHT	kg	18
-----------------	----	----



NOTES

- 01 - TOLERANCES ACCORDING TO ORIGIN STANDARD
- 02 - NUMBER OF SHEDS : 9
- 03 - ALL FERROUS PARTS ARE HOT DIP GALV. PER ASTM A-153
- 04 - DIMENSIONS IN MILLIMETERS
- 05 - FOR ORDERING INFORMATION SEE TABLE BELOW.



PART No.	GLAZED COLOR
8.1022.65-70	ANSI GRAY 70
8.1022.65	BROWN



TITLE : STATION POST INSULATOR SOLID CORE - 200 kV (BIL)			IDENTIFICATION
			DRAWING -
ORIGIN: SANTANA DESIGN IEC 168/273-CLASS C10-200-II	ELAB./DATE LUS 28-09-99	VERIF./DATE EVANDRO 28-09-99	APPROV./DATE ALDO 28-09-99
	TYPE-CAID	REVISION 1	
CODE CAD : G:\PROJ\UNI-02\STATION\			
CODE	8.1022.65	SCALE	-